PRODUCT SPECIFICATION LPT-M-C2H4 Transmitter

Digital (Modbus®) Transmitter with Electrochemical Ethylene (C₂H₄) Sensor

Dimensions: Size Weight	$5.0'' \times 5.0'' \times 2.8'' $ (127 mm x 127 mm x 71 mm) (dimensions without optional splash guard) $5.0'' \times 5.0'' \times 3.3'' $ (127 mm x 127 mm x 84 mm) (dimensions with optional splash guard) 14 ounces (400 q)
Construction	ABS / Polycarbonate blend, water/dust tight, corrosion resistant (meets IP54 standard with optional splash guard installed)
Sensor: Type Life Span	Electrochemical Approximately 3+ years (application dependent)
Gases Detected	Ethylene (C2H4)
Sensor Range	0 – 200 ppm standard
System Power	3-wire: VDC: 12-30 VDC, 3-Watts 4-wire: VAC: 12-27VAC, 3-VA
Temperature	-20°C to +50°C (-4°F to 122°F), -40°C (-40°F) with LCD heater option
Humidity	15 to 90% non-condensing
Indicators	LCD digital display, back lit, 128 X 64 pixel graphic (optional heater - applications to -40C)
Signal	Modbus® RS-485 RTU
Relay	One dry contact relay rated 2-amps @ 30v S.P.D.T.
Audible	Internal audible alarm (user controlled)
Minimum Detection	0.5 ppm (with regular calibration maintenance of sensor)
Accuracy	+/- 2% of reading @ STP, across measurement range at time of calibration with C2H4 and a calibration concentration + calibration gas concentration error
Repeatability	<2% (with regular calibration maintenance of sensor)
Sensitivity Drift	Zero: -1 to +4 ppm (with regular calibration maintenance of sensor) @ $+20$ C Span: <5% signal per month (with regular calibration of sensor)
Response Time	$<$ 60 seconds T_{90}
Resolution	Display resolution 1 ppm, sensor resolution: 0.5 ppm
Warm Up Time	2- minutes after power up (to full operation)
Cross Sensitivity	CO <60%
Safety	Automatic resetting thermal overload fuse (reset capabilities to 500 times)
Wiring	4-wire VAC/VDC, 16 awg, 4-conductor shielded network wiring (daisy chain)
Sensor Mounting	Only slightly lighter than air, 4' to 6' from the floor
Monitoring Area	5000 -7000 sq. ft.
Certifications	CSA: C22.2 NO.205-12 UL: UL508 (Edition 17): 2007 CE: EMC Directive 2004/108/EC, EN50270:2006, Type-1 & EN61010 FCC
Note	Never install gas detectors in the direct path of moving air.

Rev: 1803-1