





**QCC-M**

INSTALLER SUPPLIED LINE VOLTAGE (90-240 VAC, 50-60 HZ)

END OF LINE JUMPER (J8) INSTALLED ON "EN" ON FIRST AND LAST DEVICE IN DIGITAL NETWORK

**RLY-4**





END OF LINE JUMPER (J12) INSTALLED ON "EN" ON FIRST AND LAST DEVICE IN DIGITAL NETWORK

RELAYS OPERATE IN A "FAIL SAFE" CONFIGURATION


INDIVIDUAL 4-20 mA SIGNAL WIRE FOR EACH ANALOG DEVICE

**CXT-A-R-CCH4**



**AST-IS18**

**CXT REMOTE HOUSING**



REMOTE SENSOR TO BE MOUNTED ON OR NEAR THE CEILING

CRITICAL ENVIRONMENT TECHNOLOGIES CANADA INC.

[www.critical-environment.com](http://www.critical-environment.com)

QCC-M TO REMOTE CXT CATALYTIC METHANE SENSOR AND AST-IS18 CO2 0-4% VOL TRANSMITTER WITH RLY-4 REMOTE RELAY WIRING CONNECTION DRAWING

REV-A September 14, 2017