


ANALOG INPUT AREA




INDIVIDUAL 4-20 mA SIGNAL WIRE FOR EACH ANALOG CXT

THREE RELAY CONTROL WIRING TERMINALS. CONNECT TO COM & NC. DO NOT USE SOLID CORE WIRE.

RELAYS OPERATE IN "FAIL SAFE" CONFIGURATON.




INSTALLER SUPPLIED LINE VOLTAGE (90-240 VAC, 50-60 HZ)



DAISY-CHAIN POWER & GND WIRES RUNNING TO ADDITIONAL CXT TRANSMITTERS. NOTE THAT ONE SIGNAL WIRE MUST BE PULLED FOR EACH ADDITIONAL CXT TRANSMITTER ADDED.



(Combustible Sensor %LEL)



CRITICAL ENVIRONMENT TECHNOLOGIES CANADA INC.
www.critical-environment.com

QCC TO REMOTE CXT COMBUSTIBLE ANALOG BOARD WIRING CONNECTION DRAWING
REV-A June 13, 2017