

CENTER 265 AC Leakage Clamp Meter



CE

FEATURES:

- *0.001 mA Current Resolution.*
- *True RMS Measurement For All Applications.*
- *Backlight Function.*
- *Low Pass Filter Function.*
- *Peak Hold Function.*
- *Data Hold Function.*
- *Zero Function.*
- *Auto Power Off.*
- *Autoranging.*

CENTER®


CENTER 265 AC Leakage Clamp Meter

FEATURES

- 0.001 mA Current Resolution.
- True RMS Measurement For All Applications.
- Low Pass Filter Function.
- Backlight Function.
- Peak Hold Function.
- Data Hold Function.
- Zero Function.
- Auto Power Off.
- Autoranging.

★ 0.001 mA!

GENERAL SPECIFICATIONS

- **Numerical Display:**
4 digital liquid crystal(LCD), Maximum reading 6000.
- **Low Battery Indication:** The  is displayed.
- **Sampling Rate:** 2 Times/sec
- **Power Source:** 1.5V size AAA battery x 2
- **Auto Power Off:** 30 minute.
- **Operating Temperature and Humidity:**
0°C to 40°C(32°F to 104°F); < 80%RH
- **Storage Temperature and Humidity:**
-10°C to 60°C(14°F to 140°F); < 80%RH
- **Jaw Opening Diameter:** 23 mm
- **Dimensions/ Weight:** 206(L)×76(W)×33.5(H)mm/ Approx.270g
- **Accessories:**
Carrying Case, Batteries, Test Lead, Instruction Manual.



LED Back Light



ELECTRICAL SPECIFICATIONS

Function	Range	Resolution	Accuracy
ACmA	6.000mA/60.00mA/600.0mA	0.001mA/0.01mA/0.1mA	±1%rdg± 3dgt
ACA	6.000A/60.00A	0.001A/0.01A	±1%rdg± 3dgt
DCV	60V/600V	0.01V/0.1V	±1%rdg± 2dgt
ACV	60V/600V	0.01V/0.1V	±1%rdg± 3dgt
Ohm	600/6K/60K/600KΩ	0.1Ω/1Ω/10Ω/100Ω	±1%rdg± 2dgt
⋄))	< 60Ω		

*The specifications and other information in this catalogue are subject to change without prior notice.

CENTER
CENTER TECHNOLOGY CORP.



4F, No.415, Jung-Jeng Road, Shu-Lin Dist.,
New Taipei City 238, Taiwan
TEL: 886-2-26763926 E-Mail : center@centertek.com
FAX: 886-2-26763925 http ://www.centertek.com



Authorized Distributor
APL ASIA CO., LTD.
11/129-132 Moo.5 Lamukka Rd.,T.Kookut, A.Lamukka, Pathumthani 12130 Thailand.
TEL. 0-2995-4461-3, FAX. 0-2995-4464
www.apl-asia.com
EMAIL : sales@apl-asia.com
LINE@ : @APL-ASIA