



INTERIOR OF QCC

DIGITAL LAN

120/240VAC

INSTALLER SUPPLIED LINE VOLTAGE (90-240 VAC, 50-60 HZ)

LPT-P CIRCUIT BOARD

THREE RELAY CONTROL WIRING TERMINALS. CONNECT TO COM & NC. DO NOT USE SOLID CORE WIRE. RELAYS OPERATE IN "FAIL SAFE" CONFIGURATON.

CONNECTION TERMINAL FOR REMOTE ESH-A SENSOR.

THIS QCC + LPT-P COMBINATION MAKES A ONE, TWO, THREE OR FOUR CHANNEL GAS DETECTION MONITORING SYSTEM FOR MANY TYPES OF GAS DETECTION APPLICATIONS.

CRITICAL ENVIRONMENT TECHNOLOGIES CANADA INC. www.critical-environment.com  
 QCC TO REMOTE LPT-P MODBUS RTU WIRING CONNECTION DRAWING REV-A Feb 8, 2017

DAISY-CHAIN WIRES RUNNING TO ADDITIONAL LPT-P MODBUS TRANSMITTERS. FIRST AND LAST DEVICE IN BUS REQUIRE A TERMINATION RESISTOR.