



PRODUCT SPECIFICATION LPT-B-CL2 Transmitter

Digital (BACnet®) Transmitter with Electrochemical Chlorine (Cl₂) Sensors

Dimensions: Size	5.0" X 5.0" X 2.8" (127 mm x 127 mm x 71 mm) (dimensions without optional splash guard)
Weight	5.0" X 5.0" X 3.3" (127 mm x 127 mm x 84 mm) (dimensions with optional splash guard) 14 ounces (400 g)
Construction	ABS / Polycarbonate blend, water/dust tight, corrosion resistant (meets IP54 standard with optional splash guard installed)
Sensor: Type	Electrochemical
Life Span	Approximately 3+ years (application dependent)
Gases Detected:	Chlorine (Cl ₂)
Sensor Range:	0 – 5.0 ppm standard
System Power:	3-wire: VDC: 12-30 VDC, 3-Watts 4-wire: VAC: 12-27VAC, 3-VA
Temperature:	-20°C to +50°C (-4°F to 122°F), -40°C (-40°F) with LCD heater option
Humidity:	15 to 90% non-condensing
Indicators:	LCD digital display, back lit, 128 X 64 pixel graphic (optional heater - applications to -40C)
Signal:	BACnet® MS/TP
Relay:	One dry contact relay rated 2-amps @ 30v S.P.D.T.
Audible:	Internal audible alarm (user controlled)
Minimum Detection:	0.1 ppm (with regular calibration maintenance of sensor)
Accuracy:	+/- 0.1 ppm @ STP, across measurement range at time of calibration and at calibration concentration + calibration gas concentration error
Repeatability:	+/- 2% (with regular calibration maintenance of sensor)
Sensitivity Drift:	Zero: 0.03 ppm change/year in lab air (with regular calibration maintenance of sensor)
Response Time:	<60 seconds T ₉₀
Resolution:	Display resolution 0.1 ppm, sensor resolution: 0.1 ppm
Warm Up Time:	5- minutes after power up (to full operation)
Cross Sensitivity:	H ₂ S 20 ppm = <100, NO ₂ 10 ppm = 100, NO 50 ppm = <0.5, SO ₂ 20 ppm = <-2, CO 400 ppm = <0.1, H ₂ 400 ppm = <0.1, C ₂ H ₄ 400 ppm = <0.1, NH ₃ 20 ppm = <0.1
Safety:	Automatic resetting thermal overload fuse (reset capabilities to 500 times)
Wiring:	4-wire VAC/VDC, 16 awg, 4-conductor shielded network wiring (daisy chain)
Sensor Mounting:	Heavier than air (vehicle exhaust application: 4'-6' from the floor)
Monitoring Area:	3000 sq. ft.
Certifications: (tested to)	CSA: C22.2 NO.205-12 UL: UL508 (Edition 17): 2007 CE: EMC Directive 2004/108/EC, EN50270:2006, Type-1 & EN61010 FCC Listed by BTL
Note:	Never install gas detectors in the direct path of moving air.

Rev. 1803-1