



THREE RELAY CONTROL WIRING TERMINALS. CONNECT TO COM & NC. DO NOT USE SOLID CORE WIRE.

RELAYS OPERATE IN "FAIL SAFE" CONFIGURATON.

ANALOG INPUT AREA

INDIVIDUAL 4-20 mA SIGNAL WIRE FOR EACH ANALOG CXT

INSTALLER SUPPLIED LINE VOLTAGE (90-240 VAC, 50-60 HZ)

PWR
OUT 4-20 Toxic/O2
OUT 4-20 BRIDGE
COM

H2S sensor (PPM) (toxic)

O2 sensor (%VOL) (oxygen)

CH4 sensor (%LEL) (combustible)

DAISY-CHAIN POWER & GND WIRES RUNNING TO ADDITIONAL CXT TRANSMITTERS. NOTE THAT ONE SIGNAL WIRE MUST BE PULLED FOR EACH ADDITIONAL CXT TRANSMITTER ADDED.

THIS QCC + CXT COMBINATION MAKES A THREE CHANNEL GAS DETECTION MONITORING SYSTEM FOR HYDROGEN SULPHIDE, OXYGEN AND METHANE (OR ANY TWO TOXIC SENSORS AND ONE COMBUSTIBLE SENSOR).

CRITICAL ENVIRONMENT TECHNOLOGIES CANADA INC.
www.critical-environment.com

QCC TO REMOTE CXT TOXIC/O2 AND COMBUSTIBLE ANALOG BOARD WIRING CONNECTION DRAWING
REV-A March 9, 2016