

Loading Bays



Monitoring CO, NO₂ and Propane
FCS + LPT-P-TCO-NO2B-R
+ ESH-A-C3H8-100

Parkades - Gas & Propane Engine Exhaust



CO + C₃H₈ Monitoring
SCC-D-TCO-R + ESH-A-C3H8-100

Parkades - Variable Speed Fans




CO + NO₂ Monitoring with VFD Control
DCC-E-TCO-NO2B

Repair Shops - Gas & Diesel Engine Exhaust



CO + NO₂ Monitoring
SCC-E-TCO-NO2B

Hatcheries - Ozone Generators




Ozone (O₃) Leak Detection
DCC-B-RT + LPT-A-O3
Knowing Before Entering

Pools - Chlorination Equipment



Chlorine (Cl₂) Leak Detection
LPT-A-CL2 or LPT-M-CL2 or LPT-B-CL2

Storage Room - Gas Cylinders



Combustible Leak Detection
LPT-A-R + ESH-A-CCH4-100

Arenas - Propane Powered Ice Machines




Propane (C₃H₈) Leak Monitoring
CXT-A-IC3H8 or LPT-A-CC3H8

Arenas - Ammonia Compressors




Ammonia (NH₃) Leak Detection
DCC-B-RT + LPT-A-NH3
Knowing Before Entering

Arenas - Penalty Box/Ice Surface Area



Monitoring CO and NO₂
LPT-P-TCO-NO2B

Laboratories & Research Facilities




Oxygen (O₂) Deficiency Monitoring
LPT-A-O2 or LPT-M-O2 or LPT-B-O2

Hospitals - MRI Rooms



Oxygen (O₂) Deficiency Monitoring
DCC-MRI

Wastewater Treatment Plants




Toxic & Combustible Gases Monitoring
QCC-M + LPT-A-HS2 + LPT-A-O2 + LPT-A-CL2 + CXT-A-ICH4

Commercial Cannabis Oil Extraction




Butane (C₄H₁₀) Monitoring
QCC-M + CXT-IC4H10
Know the Air You're Breathing

Commercial Cannabis Growing Room



Carbon Dioxide (CO₂) Monitoring
AST-IS18 or AST-IS18-M

Greenhouses



Carbon Dioxide (CO₂) Monitoring
AST-IS1 or AST-IS5

Welding Shops




Monitoring CO and NO₂
DCC-E-TCO-NO2B

Wineries - Fermentation Tanks




Monitoring CO₂ and O₂ Levels
AST-IS18 + LPT-A-O2

Breweries - Fermentation & Bottling Areas



Monitoring CO₂ and O₂ Levels
AST-IS18-M + LPT-M-O2
We Care About Your Air

Bakeries - Freezer or Cooler



Refrigerant Leak Detection
ART-B-R134A or LPT-A-SR134A

Mechanical Rooms - Two Chillers




Refrigerant Leak Monitoring
LPT-A-SR407C

Hotel Rooms - Air Conditioning




Refrigerant Leak Detection
LPT-A-R + ESH-SR410A-Z

Refrigeration Systems - Relief Stack




Ammonia Vent Line Leak Detection
LPT-A-VLT-NH3-5

Refrigeration - Direct Systems



Refrigerant Leak Detection for VRV/VRF Systems
LPT-A-SR410A

Furnace Rooms



Natural Gas Monitoring
LPT-B-TCO-R + ESH-A-CCH4-100

Cold Storage / Freezer Plants



Monitoring Ammonia (NH₃)
FCS + LPT-M-NH3

Fruit Ripening Rooms



Monitoring CO and Ethylene
DCC-E-TCO-C2H4

Battery Charging Rooms



Hydrogen (H₂) Monitoring
LPT-A-CH2 or LPT-M-CH2

Pulp and Paper Mills



Monitoring O₂, Cl₂, O₃, ClO₂, & CH₄
FCS-8 + LPT-A-O2 + LPT-A-CL2 + LPT-A-O3
LPT-A-CLO2 + LPT-A-CCH4-100

Commercial Kitchens



CO & Natural Gas Leak Detection
LPT-A-COB + ESH-A-CCH4-100

LNG Large Truck Service Garages



Natural Gas Monitoring
CXT-A-R-CCH4 or CXT-D-R-CCH4

Shipping Warehouses



CO and NO₂ Monitoring
LPT-A-TCO-NO2B

Ferries - Sewage Compartment



Monitoring Hydrogen Sulphide (H₂S)
QCC-RDM + CXT-D-H2S inside + QCC-M at another entrance

Buildings on Landfill Sites




Methane (CH₄) Monitoring
LPT-A-CCH4-100 or ESH-A-CCH4-100

Fire Halls - Gas & Diesel Engine Exhaust



Monitoring CO and NO₂
DCC-E-TCO-NO2B-S

Bus Barns - Gas & Diesel Engine Exhaust



Monitoring CO and NO₂
FCS-M + LPT-P-TCO-NO2B